

UKCA DECLARATION OF CONFORMITY

We, DWYER INSTRUMENTS, LLC
102 Indiana Highway 212
Michigan City, Indiana, 46360 USA
declare under our sole responsibility that

Series 685 Differential Pressure Transmitter

to which this declaration relates is in conformity with the following UK Regulations and Statutory Instruments:

UK SI 2012 No. 3032 The Restriction of the Use of Certain Hazardous Substances in Electrical and Electronic Equipment Regulations 2012

UK SI 2016 No. 1091 Electromagnetic Compatibility Regulations 2016

UK SI 2016 No. 1101 Electrical Equipment (Safety) Regulations 2016

BS EN 61326-1:2013 Electrical Equipment for Measurement, Control and Laboratory Use - EMC Requirements – Part 1: General Requirements

BS EN 61010-1:2010 Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

EN 61000-4-2:2009 Electromagnetic Compatibility (EMC) - Part 4-2: Testing and Measurement Techniques - Electrostatic Discharge Immunity Test

EN 61000-4-3:2010 Electromagnetic Compatibility (EMC) - Part 4-3: Testing and Measurement Techniques - Radiated, Radio-Frequency, Electromagnetic Field Immunity Test

EN 61000-4-6:2009 Electromagnetic Compatibility (EMC) - Part 4-6: Testing and Measurement Techniques - Immunity to Conducted Disturbances, Induced By Radio-Frequency Fields

EN 55011:2010 Industrial, Scientific and Medical Equipment – Radio-frequency Disturbance Characteristics – Limits and Methods of Measurement

EN 50581:2012 Technical Documentation for the Assessment of Electrical and Electronic Products with Respect to the Restriction of Hazardous Substances

The authorized representative located in the UK is

Dwyer Instruments UK, LLC
Unit 16, The Way Estate, London Road
High Wycombe, Bucks HP11 1LH, UK
(+44) (0) 1494 461707

On behalf of Dwyer Instruments, LLC



Doug McCall
Senior Regulatory Engineer
April 27, 2022
Michigan City, Indiana, USA