

DWYER INSTRUMENTS, INC.

102 INDIANA HIGHWAY 212 | P.O. BOX 373 MICHIGAN CITY, IN 46360-1956

DWYER-INST.COM

EU DECLARATION OF CONFORMITY

12

We,

Dwyer Instruments, Inc. 102 Indiana Highway 212 Michigan City, IN 46360 USA +1-219-879-8868

declare under our sole responsibility our Series CDT and CDTR Duct Mount Carbon Dioxide/Temperature/Relative Humidity Transmitters to which this declaration relates are in conformity with the following EU Directives and harmonized Standards:

Directive 2014/108/EC Electromagnetic Compatibility (EMC)

EN 61326-1:2006 Electrical Equipment for Measurement, Control and Laboratory Use - EMC Requirements - Part 1: General Requirements

IEC 61000-4-2:2008 Electromagnetic Compatibility (EMC) - Part 4-2: Testing and Measurement Techniques - Electrostatic Discharge Immunity Test

IEC 61000-4-3:2010 Electromagnetic Compatibility (EMC) - Part 4-3: Testing and Measurement Techniques - Radiated, Radio-Frequency, Electromagnetic Field Immunity Test

IEC 61000-4-4:2010 Electromagnetic Compatibility (EMC) - Part 4-4: Testing and Measurement Techniques - Electrical Fast Transient/Burst Immunity Test

IEC 61000-4-6:2008 Electromagnetic Compatibility (EMC) - Part 4-6: Testing and Measurement Techniques - Immunity to Conducted Disturbances, Induced By Radio-Frequency Fields

EN 55011:2010 Industrial, Scientific and Medical Equipment - Radio-Frequency Disturbance Characteristics - Limits and Methods of Measurement

The authorized representative located within the Community is:

Comhas Srl Via Matteotti 66 200092 Cinisello Balsamo Milano, Italy +39 335.7064538

On behalf of Dwyer Instruments, Inc.,

Doug McCall

Senior Regulatory Engineer

July 31, 2021

Michigan City, Indiana, USA