

DWYER INSTRUMENTS, INC.

102 INDIANA HIGHWAY 212 | P.O. BOX 373 MICHIGAN CITY, IN 46360-1956

DWYER-INST.COM

EU DECLARATION OF CONFORMITY

14

We,

Dwyer Instruments, Inc. 102 Indiana Highway 212 Michigan City, IN 46360 USA +1-219-879-8868

declare under our sole responsibility our Series GSTC Carbon Monoxide/Nitrogen Dioxide Gas Transmitter to which this declaration relates is in conformity with the following EU Directives and harmonized Standards:

Directive 2011/65/EU Restriction of Certain Hazardous Substances in Electrical and Electronic Equipment (RoHS)

Directive 2014/30/EU Electromagnetic Compatibility (EMC)

EN 61326-1:2013 Electrical Equipment for Measurement, Control and Laboratory Use - EMC Requirements - Part 1: General Requirements

IEC 61000-4-2:2008 Electromagnetic Compatibility (EMC) - Part 4-2: Testing and Measurement Techniques - Electrostatic Discharge Immunity Test

IEC 61000-4-3:2010 Electromagnetic Compatibility (EMC) - Part 4-3: Testing and Measurement Techniques - Radiated, Radio-Frequency, Electromagnetic Field Immunity Test

IEC 61000-4-4:2004+A1:2010 Electromagnetic Compatibility (EMC) - Part 4-4: Testing and Measurement Techniques - Electrical Fast Transient/Burst Immunity Test

IEC 61000-4-5:2005 Electromagnetic Compatibility (EMC) - Part 4-5: Testing and Measurement Techniques - Surge Immunity Test

IEC 61000-4-6:2008 Electromagnetic Compatibility (EMC) - Part 4-6: Testing and Measurement Techniques - Immunity to Conducted Disturbances, Induced By Radio-Frequency Fields

EN 55011:2009+A1:2010 Industrial, Scientific and Medical Equipment - Radio-Frequency Disturbance Characteristics - Limits and Methods of Measurement

EN 55022:2010 Information Technology Equipment – Radio Disturbance Characteristics – Limits and Methods of Measurement

EN 55024:2010 Information Technology Equipment - Immunity Characteristics - Limits and Methods of Measurement

The authorized representative located within the Community is:

Comhas Srl Via Matteotti 66 200092 Cinisello Balsamo Milano, Italy +39 335.7064538

On behalf of Dwyer Instruments, Inc.,

Doug McCall Senior Regulatory Engineer July 31, 2021 Michigan City, Indiana, USA