



## Series MSX and MSX Pro Magnesense® Pressure Transmitter

---

### Specifications - Installation and Operating Instructions

#### QUICK START GUIDE

1. **Mount** transmitter with pressure ports facing down. Do not over-tighten mounting screws.
2. **Attach wires** following diagram on reverse side.
3. **Set Zero Calibration.** Apply zero pressure to both pressure ports on transmitter at the same time you press ZERO button for 3 seconds.
4. **Scan** QR code with smart device to open the product web page for additional resources.




MSX




MSX PRO

## WIRING INFORMATION



**4-20 mA**



**3-wire voltage (with DC supply)**

See online User Guide for AC wiring.

Printed in U.S.A. 8/20  
FR# 444572-00 Rev. 1

©Copyright 2020 Dwyer Instruments, Inc.